

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE

No. 009

Date :20-03-2026

It is certified that an inspection team headed by Pavithra B S Sr. Analyst RDWSD (Name of Officers with designation) from RDWSD District Laboratory Bangalore (Name of Department/ Office) inspected SACRED HEART ACADEMY Situated at Mylasandra Gate, Beguru P.O, Bangalore-560114 (Name & Address of the School) on 16-03-2026 and the basis of Water Test Report number 009 dated 18-03 -2026 of RDWSD District Laboratory Certified that the SACRED HEART ACADEMY Situated Mylasandra Gate, Beguru P.O, Bangalore-560114. (Name of school) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T Govt.

The above valid for a period of 19-03-2027

Signature with Seal

Name

Designation

Name & Address of the Department: RDWSD Division

Bangaluru

Executive Engineer
Rural Drinking water
and Sanitation Division
Bangalore (Urban) Bangalore
Executive Engineer



To

SACRED HEART ACADEMY

Mylasandra Gate, Beguru P.O,

Bangalore-560114



RURAL DRINKING WATER & SANITATION DEPARTMENT, GoK
Bengaluru Urban Divisional Laboratory-Banashankari, Bangalore-560070.
NABL Accredited Laboratory Bangalore urban

TEST REPORT					
Address of the sampling location :- SACRED HEART ACDEMY Mylasandra Gate, Begur P.O, Bangalore-560114				Report date: 18/03/2026	
				Report Number:009	
				Reference: TRF	
				Sample Code:009	
				Date of Sample collection: 16/03/2026	
				Analysis start date: 17/03/2026	
				Analysis completion date: 18/03/2026	
				Sample quantity: 1 Liter	
Sample Particulars: R O water					
Sl. No	Test	Results	Acceptable Limit IS 10500 : 2012 RA:2018	Permissible Limit IS 10500 : 2012 RA:2018	Protocol
Description: Colourless liquid					
1	pH Value @25°C Temp	6.9	6.5 – 8.5	No relaxation	IS 3025 (Part-11) : 2022
2	Specific Conductance, μ S/cm @25°C Temp	80	-	-	IS 3025 (Part-14) : 2013
3	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5 & 6):2018
4	Colour, Hazen Units	< 1.0	5	15	IS 3025 (Part-4) :2021
5	Turbidity, NTU	0.0	1	5	IS 3025 (Part-10) : 2023
6	Total Dissolved Solids, mg/l @180°C	50	500	2000	IS 3025 (Part-16) : 2023
7	Alkalinity as CaCO ₃ , mg/l	12.6	200	600	IS 3025 (Part-23) : 2023
8	Total Hardness as CaCO ₃ , mg/l	15.9	200	600	IS 3025 (Part-21) : 2009
9	Calcium as Ca, mg/l	3.2	75	200	IS 3025 (Part-40) : 1991
10	Magnesium as Mg, mg/l	1.9	30	100	IS 3025 (Part-46) : 2023
11	Chloride as Cl, mg/l	7.6	250	1000	IS 3025 (Part-32) : 1988
12	Sulphate as SO ₄ , mg/l	11.2	200	400	IS 3025 (Part-24) : 2022
13	Fluoride as F, mg/l	0.3	1	1.5	APHA 24 th Edition
14	Nitrate as NO ₃ , mg/l	3.6	45	No relaxation	APHA 24 th Edition
15	Iron as Fe, mg/l	<0.1	1	No relaxation	IS 3025 (Part-53) : 2003
Remark: The above given sample conforms to the Acceptable limits as per IS 10500:2012 drinking water specifications for the above mentioned parameters only.					
Analysed by: <i>Megha K. S</i> Senior Analyst/Junior Analyst			Authorized Signatory: <i>Pavithra B.S</i> Technical Manager: Pavithra B.S		



RDWSD/WQMSP/TeR/01

Note:

- 1) The above results relate only to the sample tested.
- 2) The report shall not be reproduced except in full without the prior approval of the Quality Manager.
- 3) Traceability: Traceability of measurements is established using CRMs traceable to National/International standards.
- 4) Samples will be discarded after 15 days from the date of report generation.
- 5) Decision rule is applicable as per the procedure mentioned in RDWSD/WQMSP/DR-01

---END---



SACRED HEART ACADEMY

Mylasandra Gate, Begur P.O, Bangalore – 114.



:9901963485-8618005683:



sacredheartacademy25@gmail.com

03-03-2026

To

The Executive Engineer
Rural Drinking Water & Sanitation Dept (RDWSD)
Bangalore Urban Division
Banashankari
Bengaluru-560070

Subject: Request for Inspection and Issuance of Safe Drinking Water & Sanitary Condition Certificate (Annexure C) for CBSE Affiliation

Respected Sir,

I respectfully submit that our institution, Sacred Heart Academy, Mylasandra Gate, Begur Hobli, Bengaluru – 560068, is in the process of applying for affiliation with the Central Board of Secondary Education (CBSE).

As per CBSE norms, we are required to submit the Safe Drinking Water and Sanitary Condition Certificate (Annexure C), duly signed and sealed by the authorized officer of the Public Health Engineering Department (PHED) or the competent local authority.

In this regard, we kindly request you to:

- # Conduct an inspection of our school premises at your convenience.
- # Verify the drinking water facilities and sanitary conditions.
- # Issue and sign the prescribed Annexure C certificate in the CBSE format.

We assure you that our school maintains proper drinking water facilities and hygienic sanitation conditions as per Government norms.

We request you to kindly process our application at the earliest to enable us to complete the CBSE affiliation formalities within the stipulated time.

Thanking you in anticipation of your support.

Yours faithfully,

Sr. Sherin John

Principal

Sacred Heart Academy

Mylasandra Gate Begur Post,
Bengaluru-560114

