

Annexure D

BUILDING SAFETY CERTIFICATE

No. AEE/No.1/PWD/SD/BS/2025-26/589

Dated: 29/10/2025

It is certified that the existing building **Sacred Heart Academy, Mylasandra Gate, Begur Post, Bangalore – 560 114** is having block(s)/Floor(s) as per details below:


Detail of Block(s) in school	Block (1)	Block (2)	Block (3)	Block (4)	Block (5)	Block (6)
No. of Floor(s) in the Academic Blocks	GF + 1 st and 2 nd Floor	GF + 1 st and 2 nd Floor	GF + 1 st Floor	-	-	-

The building is owned / occupied by **Sacred Heart Academy, BANGALORE** have complied with the Building safety requirements in accordance with National Building code Rules, and verified by the officers concerned of **Keystone Engineering Solutions – QC Lab, No.06, Corner Building, Ground & First Floor, 3rd Main Gnanagana Nagar, Mariyappana Palya, Bangalore** in the presence of **Principal, Sacred Heart Academy School** and that the building/premises is fit for occupancy for running school with effect from **29-10-2025** for a period of **One academic year** in accordance with rule and subject to compliance of the specific conditions as appended.

1. Regular Maintenance of Building & Plumbing works have to be taken up throughout the year.
2. Cracks are found on the existing walls. Hence, these cracks may be treated with Grouting method.
3. Dampness are found on the existing walls. Hence, Dampness may be treated with Waterproofing method
4. Renewal of fire safety Certificate
5. Any Major damages, if any, observed in future such damages must be rectified and intimated to the concerned competent authority.
6. The Certificate is not be applicable for any further construction / addition / alteration / modification of building / plumbing / firefighting works which will be taken, after the issuance of the certificate

Issued on **29-10-2026** at Bangalore by **Assistant Executive Engineer, No.1 Pwd South Sub Division, Bengaluru** by

Signature with Seal :


Assistant Executive Engineer
No. 1, PWD South Sub Division,
K.R. Circle, Bangalore-560 001

